



Cedarbrook Drinking Water System

Municipal Summary Report

(Prepared in accordance with Schedule 22 of Ontario Regulation 170/03)

January 1st to December 31st, 2017

Schedule 22; Section 22-2**Section 1**

List Requirements of the Act, the Regulations, the system's approval and any order the system failed to meet (non-compliances) at any time during this reporting period, the duration of each non-compliance and describe the action taken to correct each non-compliance listed in this section.

Act & Regulations
There were no non-compliances with respect to the SDWA or supporting regulations identified during this reporting period.
System Municipal Drinking Water License and Drinking Water Works Permit
There were no non-compliances with respect to the Municipal Drinking Water License and Drinking Water Works Permit identified during this reporting period.
Orders
There were no provincial orders issued during this reporting period.
Best Practice Issues and Recommendations
There were no recommendation or Best Management Practices issued by MOECC during this reporting period.

Section 2

In order to assist the owner in assessing the capability of the system to meet existing and planned uses of the system, The Township of Oro-Medonte monitors and compiles volume and flow rates. Data compiled for 2017 is as follows:

Source	Maximum Volume (m³/day)	% Approved Capacity	Monthly Average (m³/day)	% Approved Capacity	Monthly Distribution Flow (m³)
WELL 1 Approved Capacity			104 (160.8 L/MIN)		
January	9	9	6.42	6	423
February	7	7	6.39	6	379
March	8	8	6.19	6	401
April	9	9	6.6	6	420
May	9	9	7	7	457
June	10	10	6.87	7	435
July	9	9	6.97	7	454
August	10	10	7.06	7	464
September	17	16	9.07	9	410
October	17	16	12.94	12	401
November	12	12	6.83	7	392
December	10	10	6.97	7	436
COMMENTS					

Source	Maximum Volume (m ³ /day)	% Approved Capacity	Monthly Average (m ³ /day)	% Approved Capacity	Monthly Distribution Flow (m ³)
WELL 2 Approved Capacity			104 (160.8 L/MIN)		
January	10	10	7.23	7	423
February	8	8	7.14	7	379
March	10	10	6.74	6	401
April	10	10	7.4	7	420
May	12	12	7.74	7	457
June	12	12	7.63	7	435
July	10	10	7.68	7	454
August	11	11	7.9	8	464
September	10	10	4.6	4	410
October	0	0	0	0	401
November	9	9	6.23	6	392
December	10	10	7.1	7	436
COMMENTS					

Flow requirements listed in the PTTW were not exceeded in 2017.
MOECC Final Inspection Rating: 100%