



Warminster Drinking Water System

Municipal Summary Report

(Prepared in accordance with Schedule 22 of Ontario Regulation 170/03)

January 1st to December 31st, 2017

Schedule 22; Section 22-2**Section 1**

List Requirements of the Act, the Regulations, the system's approval and any order the system failed to meet (non-compliances) at any time during this reporting period, the duration of each non-compliance and describe the action taken to correct each non-compliance listed in this section.

Act & Regulations
There were no non-compliances with respect to the SDWA or supporting regulations identified during this reporting period.
System Municipal Drinking Water License and Drinking Water Works Permit
There were no non-compliances with respect to the Municipal Drinking Water License and Drinking Water Works Permit identified during this reporting period.
Orders
There were no provincial orders issued during this reporting period.
Best Practice Issues and Recommendations
There were no recommendation or Best Management Practices issued by MOECC during this reporting period.

Section 2

In order to assist the owner in assessing the capability of the system to meet existing and planned uses of the system, The Township of Oro-Medonte monitors and compiles volume and flow rates. Data compiled for 2017 is as follows:

Source	Maximum Volume (m³/day)	% Approved Capacity	Monthly Average (m³/day)	% Approved Capacity	Monthly Distribution Flow (m³)
WELL 1 Approved Capacity			889.9 (782 L/MIN)		
January	175	20	76.81	9	4411
February	180	20	69.75	8	3609
March	170	19	72.68	8	4286
April	203	23	93.27	10	5431
May	232	26	82.06	9	5595
June	214	24	87.4	10	5417
July	223	25	88.03	10	5678
August	199	22	110.19	12	6100
September	190	21	97.3	11	5511
October	196	22	95.65	11	5682
November	189	21	89.27	10	5454
December	189	21	92.81	10	6107
COMMENTS					

Source	Maximum Volume (m ³ /day)	% Approved Capacity	Monthly Average (m ³ /day)	% Approved Capacity	Monthly Distribution Flow (m ³)
WELL 3 Approved Capacity			889.9 (618 L/MIN)		
January	176	20	70.97	8	4411
February	169	19	68.64	8	3609
March	180	20	72.45	8	4286
April	193	22	87.5	10	5431
May	384	43	96.39	11	5595
June	185	21	87.5	10	5417
July	205	23	94.87	11	5678
August	220	25	86.1	10	6100
September	344	39	98.9	11	5511
October	199	22	98.03	11	5682
November	194	22	88.07	10	5454
December	203	23	94.71	11	6107
COMMENTS					

Flow requirements listed in the PTTW were not exceeded in 2017.
 MOECC Final Inspection Rating: 100%