

Fire Protection Survey Services™

2403 Fairgrounds Road
Washago, Ontario, Canada, L0K 2B0

Telephone: (249) 359-7231

E-mail: fpss@xplornet.ca Website: www.fpss.ca

Fire Department Water Tanker Shuttle Accreditation

Presented To: Township of Oro-Medonte

ACCREDITED FIRE STATIONS

Fire Station #1 Shanty Bay

Fire Station #2 Hawkestone

Fire Station #3 Horseshoe Valley

Fire Station #4 Rugby

Fire Station #5 Warminster

Fire Station #6 Moonstone

Date Test Passed: October 28, 2017

Flow Achieved: 435 I.G.P.M. 1975 LITERS/MIN.

Two (2) Hour Test Time

Signed: Peter J. Rose

Peter J. Rose, C.E.T., F.P.T.
Senior Fire Protection Specialist
Senior Loss Control Specialist

